





Type		Description	Installation	Lamps		Qty	Location	Comments
				Type	Colour			
A		3x28W (1200x600mm) recessed, low brightness fluorescent fitting, with 3m cordset and 5A plugtop complete with electronic control gear	Recessed in ceiling	3x28W T5, electronic control gear	Cool White		Office's	Phillips / Voltex or equal and approved
A1		3x28W (1200x600mm) recessed, low brightness fluorescent fitting, with 3m cordset and 5A plugtop complete with electronic control gear, with Dali dimmable electronic control gear	Recessed in ceiling	3x28W T5, dimmable electronic control gear	Cool White		Office's	Phillips / Voltex or equal and approved
AE		3x28W (1200x600mm) recessed, low brightness fluorescent fitting, with 3m cordset and 5A plugtop complete with electronic control gear, with 30min emergency battery back up.	Recessed in ceiling	3x28W T5, electronic control gear	Cool White		Office's	Phillips / Voltex or equal and approved
B		7W Dimmable L.E.D. Downlighter, inclusive of holder.	Recessed in ceiling	7W L.E.D.	Cool White		Office's	Phillips or equal and approved


#### NOTES

Quantities are to be confirmed by contractor

All luminaires and lamps to be marked with manufacturers details, model numbers and production date/batch number.



All electronic ballasts are to be Osram or Phillips

					ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE:  <b>SARS I.T. CENTRE REFURBISHMENT</b>    <b>Luminaire Schedule</b>
					<b>A.M</b>		<b>09/06/2015</b>		<b>A4</b>	
					PROJ No.:		DWG No	REV	SCALE	
					<b>14075</b>		<b>500</b>	<b>0</b>	<b>nts</b>	
<b>0</b>	Original Issue			11/09/15						
REV	DESCRIPTION			BY	DATE	CHKD	FILE NAME: 14075_500_0		SHEET:	<b>1 of 2</b>

 <b>IBUYA</b> Consulting Engineers <i>"POWERING DEVELOPMENT"</i>	BLOCK D ESSEX PARK 48 ESSEX TERRACE WESTVILLE P.O. BOX 1692 WANDSBECK 3631  TEL: +27 (031) 2667831 FAX: +27 (031) 2667831 E-mail: ibuya@ibuya.co.za
---	--




BLOCK D  
ESSEX PARK  
48 ESSEX TERRACE  
WESTVILLE  
P.O. BOX 1692  
WAANDSBECK 3631  
TEL: +27 (031) 2667831  
FAX: +27 (031) 2667831  
E-mail: ibuya@ibuya.co.za

Type		Description	Installation	Lamps		Qty	Location	Comments
				Type	Colour			
B		3x14W (600x600mm) recessed low brightness flourscent fitting with aliminium optics with 3m cordset and 5A plugtop, complete with electronic control gear	Recessed in ceiling	3x14W T5, electronic control gear	Cool White		Office's	Phillips / Voltex or equal and approved
BE		3x14W (600x600mm) recessed low brightness flourscent fitting with aliminium optics with 3m cordset and 5A plugtop, complete with electronic control gear, with 30min battery back up.	Recessed in ceiling	3x14W T5, electronic control gear	Cool White		Office's	Phillips / Voltex or equal and approved

#### NOTES

Quantities are to be confirmed by contractor  
All luminaires and lamps to be marked with manufacturers details, model numbers and production date/batch number.  
All electronic ballasts are to be Osram or Phillips

					ENGINEER:	DRAWN:	DATE:	CHKD	P SIZE	TITLE:  <b>SARS I.T. CENTRE REFURBISHMENT</b>  <b>Luminaire Schedule</b>	<div><div>BLOCK D ESSEX PARK 48 ESSEX TERRACE WESTVILLE P.O. BOX 1692 WANDSBECK 3631  TEL: +27 (031) 2667831 FAX: +27 (031) 2667831 E-mail: ibuya@ibuya.co.za</div></div>
					<b>A.M.</b>		<b>09/06/2015</b>		<b>A4</b>		
					PROJ No.:		DWG No	REV	SCALE		
					<b>14075</b>		<b>500</b>	<b>0</b>	<b>nts</b>		
<b>0</b>	Original Issue		11/09/15								
REV	DESCRIPTION	BY	DATE	CHKD	FILE NAME:	13003_500_0	SHEET:	<b>2 of 2</b>			