

Bidder question

Good Day

Please assist with the below query specifications for electrical components on Bill No.8 (PV Conduit);

- NO1: Size of DB
- NO2: Size of cable tray
- NO3: Which cable tray supports
- NO4: Depends on NO2
- NO5: Size of trunking
- NO6: Which cable tray supports
- NO7: For which trunking
- NO9: Which color power skirting
- NO10: Same as NO9
- NO12: Which color GPW
- NO13: What sizes
- NO16: What type Din rail or samite
- NO18: What type of 4x4 boxes
- NO20: Which type

Response to Bidder Question

- NO1: Size of DB... **1000mm x 400mm x 120mm**
- NO2: Size of cable tray... **300mm**
- NO3: Which cable tray supports... **for Soffit Suspension 300mm Cable Trays**
- NO4: Depends on NO2
- NO5: Size of trunking... **300mm**
- NO6: Which cable tray supports... **Soffit Suspension for 300mm**
- NO7: For which trunking... **300mm**
- NO9: Which color power skirting... **Motor Craft Grey**
- NO10: Same as NO9
- NO12: Which color GPW ... **L1 - Red, L2 - Yellow, L3 - Blue, Neutral - Black, Earth - Green-Yellow**
- NO13: What sizes... **2,5mm dia**
- NO16: What type Din rail or samite.. **DIN Rail (EN60715 or Equivalent)**
- NO18: What type of 4x4 boxes... **PVC**
- NO20: Which type