

PHASE III WORKS

**ELECTRICAL LEGEND**

▷ NORMAL POWER  
White plug

▷ Dedicated Power  
180° red plug

▷ UPS POWER  
45° blue Plug

⊙ SCHUKO 2 Pin

⊙ POWERPOLE

▷ DATA

▷ VOICE

**CLUSTERS**

Minimal Cluster Spec

Typical Cluster Spec

Cashiers Spec

VOIP Cluster Spec

Fax Station

VOIP Fax Station

Consultant Network Point

Network Printer

VOIP Network Printer

VOIP MultiFunction Device

VOIP Stand-alone Phone

Corporate connection or  
Electropion Unit - STD.

Corporate connection or  
Electropion Unit - UPS.

1

2

3

4

5

6

7

8

9

10

11

12

13

4

LINE INDICATES LOCATION AT  
POWER SKIRTING / WALL / PARTITION  
THAT SUPPLY IS TO BE PULLED  
FROM.

**CABLE RETICULATION**

2. TRUNK POWER SKIRTING

300mm CABLE TRAY

150mm CABLE TRAY

**DROPS & CORES**

CABLE DROP from Cable  
Tray to Power Skirting

≡ 115mm CORE - Horizontal.

+ 115mm CORE - Through SLAB.

**NOTES**

5 X PLUGS (MAX) TO A 2AMP 5KVA CIRCUIT  
BREAKER.

PATCH ROOM UPS PLUGS TO BE CONNECTED  
TO SERVER ROOM UPS.

ALL PLANS AND DOCUMENTS ARE THE SOLE  
PROPERTY OF SARS FACILITIES SPACE PLANNING.  
NO REPRODUCTION MAY BE MADE WITHOUT  
THE WRITTEN CONSENT OF SARS FACILITIES.  
NOTE : ALL DIMENSIONS MUST BE VERIFIED ON  
SITE BEFORE THE COMMENCEMENT OF WORK

AMENDMENT SCHEDULE

| DATE | NO | AMENDMENT |
|------|----|-----------|
|      |    |           |

DATE 02/2008

SCALE 1:100 (A1)

DRAWN BY ACF

ACC MNGR TH

BUILD CODE HO-01-PT

DWG NO lehae-A-01

PROJECT FMP 119

AMEND NO P19

CLIENT APPROVAL SIGNATURE  
AND DATE

Building Name

**BLOCK A**

Drawing Description

**ELEC-DATA-VOICE**

Floor Level

**LEVEL A-01**

**SARS**

SPACE PLANNING &  
BUILDING FACILITIES  
MANAGEMENT