

Questions and Answers for RFP 28/2016

SARS requested the prospective bidders to provide questions during the week of 16 to 25 November 2016

Below is the response from SARS

Question	Answer
<p>We attended the compulsory site meeting and signed the attendance register but we did not receive the attendance certificate to attach on our tender submission.</p> <p>Can you clarify if the attendance certificate is not a required returnable document?</p>	<p>SARS will utilise the attendance register to check and verify your attendance of the compulsory briefing session.</p>
<p>Are there any drawing to show the Layout of the Ground Floor and the Sixth Floor</p>	<p>Yes.</p> <p>The drawings are uploaded on the SARS website</p>
<p>Make and model</p>	<p>Please refer to the specification, which outline the requirements</p>
<p>How many units</p>	<p>Please see as part of the tender documents, layout drawings for Ground and Sixth Floors, as well as schedule of equipment attached to each specification or the BOQ which all detail the quantity of indoor units to be installed and thereafter maintained. These are to be part of a Variable Refrigerant Flow(VRF) system so the Outdoor units required to serve the indoor unit requirements listed will be in accordance with the VRF selection that the tenderer offers – this may consist of one larger outdoor unit or two smaller outdoor units or</p>

	<p>some other configuration and is dependent on the manufacturer. I would council the prospective bidder to approach suitable manufacturer's with whom they have a relationship and get the manufacturer to do a system selection based on the tender documents provided. It should be noted that a space of approximately 3600 mm x 765 mm each has been allocated for the ground floor and sixth floor outdoor units on the roof</p>
--	--