



GENERAL NOTES	
1.	THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ARCHITECTS DRAWINGS.
2.	ALL DIMENSIONS ARE IN mm AND ARE TO BE CHECKED ON SITE. ANY DISCREPANCIES TO BE BROUGHT TO THE ATTENTION OF THE ENGINEER.
3.	ALL LOAD BEARING BRICKWORK TO HAVE A MINIMUM CRUSHING STRENGTH OF 14MPa, MORTAR CLASS 1 - 1.3.
4.	CONCRETE COVER TO REINFORCING TO BE MAINTAINED BY THE USE OF PLASTIC SPACERS OR PRECAST CONCRETE BLOCKS WITH BINDING WIRRES CAST IN.
5.	REINFORCED CONCRETE :- REQUIRED CHARACTERISTIC CUBE STRENGTH AT 28 DAYS. FOUNDATIONS 25 MPa R.C. WALLS 30 MPa BEAMS 30 MPa SUSPENDED SLABS 30 MPa SLABS 30 MPa SLABING LAYER 15 MPa
6.	ALL REINFORCEMENT TO BE INSPECTED BY THE ENGINEER PRIOR TO CASTING OF CONCRETE. MINIMUM 1 DAY'S NOTICE IS REQUIRED FOR INSPECTION.
7.	CONCRETE COVER TO REINFORCEMENT SHALL BE AS FOLLOWS : FOUNDATIONS 50 mm COLUMNS 30 mm R.C. WALLS 30 mm BEAMS 30 mm SUSPENDED SLABS 20 mm SLABS 20 mm
8.	ALL WORK SHALL COMPLY WITH SABS 1200
9.	DESIGN HAS BEEN CARRIED OUT IN ACCORDANCE WITH SABS 0100, 0160, 0162, 0163 & 1064 AS APPLICABLE.
10.	DESIGN HAS BEEN CARRIED OUT IN ACCORDANCE WITH SABS 0100.
CONSTRUCTION	
A1	

REV	DATE	DRAWN	AMENDMENTS
PROJECT:			
SARS STATE WAREHOUSE, BAYHEAD ROAD DURBAN			
TITLE:			
PROPOSED CANOPY DESIGN			

DESIGNED: BAZI DUKHAN	DRAWING
DRAWN: SR	
DATE: 26-09-2017	BD-719-ST-124-P-00

BAZI DUKHAN CONSULTING ENGINEERS	46 SWAPO ROAD (BROADWAY) DURBAN 4001 TEL: 031 363 2106 FAX: 031 363 0053 EMAIL: bazi@bazedukhan.co.za
----------------------------------	--

PRELIMINARY
