

QUESTIONS AND ANSWERS

| QUESTIONS | SARS ANSWERS |
|---|--|
| <p>We sincerely request a copy of drawings for your DBs Panels so we can be able to quote accordingly.</p> | <p>There currently are no drawings of the DBs design and layout. The line diagrams can be used to determine the DB sizes and layout. The line diagrams should be sufficient info to determine the size of the DB to submit a quote</p> <p>MLV B extension is specified as a prisma DB. The other DBs can be of any manufacturer or supplier.</p> |
| <p>Please advise if one can still bid not having attended the site visit?</p> | <p>Please note that the site visit was compulsory as per the tender document.</p> |
| <p>Kindly assist with Distribution boards Single line Drawings which are appearing in the Bill of Quantities for this project, they are not captured on the uploaded documents.</p> | <p>Please note that the drawings have been uploaded on SARS website</p> |
| <p>Kindly assist with providing the below drawings</p> | <p>Take note that the drawings are also published on the SAR Website.</p> |

| DRAWING REGISTER | |
|---|--|
| <u>A-1736-07-00-3XX</u> | <u>LIGHTING LAYOUT</u> |
| A-1736-07-00-301 RA | GROUND FLOOR |
| | |
| <u>A-1736-07-00-5XX</u> | <u>CABLE RETICULATION</u> |
| A-1736-07-00-501 RB | DATA CENTRE - CEILING RETICULATION LAYOUT |
| A-1736-07-00-502 RB | DATA CENTRE - ACCESS FLOOR RETICULATION LAYOUT |
| A-1736-07-00-503 RA | DATA CENTRE - NEW DB BOARD LOCATION LAYOUT |
| | |
| <u>A-1736-07-00-7XX</u> | <u>SINGLE LINES</u> |
| A-1736-07-00-701 RA | PDU SCHEMATIC DIAGRAM |
| A-1736-07-00-702 RA | DB-GEN/A SLD |
| A-1736-07-00-703 RA | DB-UPS/A SLD |
| A-1736-07-00-704 RA | CHILLER CHANGE OVER |
| A-1736-07-00-705 RA | DB-UPS/B EXTENSION SLD |
| | |
| <p>If we use a subcontractor, can we use their references/appointment letters? Will the subcontractors references/appointments be allocated points on behalf of the main contractor</p> | <p>No you cannot be evaluated on subcontractors' information as the main bidder.</p> <p>Your question is only applicable for Joint Venture, which will require Joint Venture agreement</p> |